



- A. SERVICE SADDLE CLAMPS
- B. 1" PACK JOINT CORPORATION STOP
- C. 1" HIGH DENSITY POLYETHYLENE PE408 (SDR 9) W/ TRACER WIRE
- X D. 1" YOKEBOX VALVE - PACK JOINT
- X E. 1"x1" YOKE BOX W/ DUAL CHECK OUTLET & METER READING LID OPTION
- F. 5/8"x3/4" METER (INSTALLED BY THE TOWN)
- X G. 5/8"x3/4" OR 1" EXPANSION CONNECTION
- X H. 1" IPS OUTLET
- I. 1"x6" BRASS NIPPLE
- J. CUSTOMER SHUT-OFF VALVE & BOX (TO BE MAINTAINED BY PROPERTY OWNER)

X THESE COME AS ONE COMPOSITE UNIT

WATER SERVICE CONNECTION (3/4" OR 1" METER)

NOTE: STAINLESS STEEL INSERTS SHALL BE USED AT ALL P.E. CONNECTIONS TO PACK JOINT FITTINGS.